



Certificate of Compliance

Clean Agent Fire Extinguishing Systems

This certificate is issued for the following equipment:

FIRETRACE Pre-Engineered, Automatic Direct, Fire Detection and Extinguishing System, Models DLP-300, DLP-600, and DLP-1200

This is to certify that the company indicated below is listed in the FM Approvals Fire Protection Approval Guide and is eligible to use the FM Approved Mark on the FIRETRACE Pre-Engineered, Automatic Direct, Fire Detection and Extinguishing System, Models DLP-300, DLP-600, and DLP-1200, in agent storage capacities of 3, 6, and 12 pounds (1.4, 2.7 and 5.5 kg) respectively of Great Lakes Chemical FM-200[®] Clean Extinguishing Agent for the total flooding protection of an enclosed volume where the likely hazard is flammable liquids. For use in ambient temperatures between 32° and 130°F (0° and 54°C). Automatic actuation and agent discharge of FIRETRACE[®] tubing by direct flame impingement. Maximum protected volume 250 ft³ (7 m³). Correspondingly smaller volumes of 62.5 ft³ (1.75 m³) and 125 ft³ (3.5 m³) may be protected with the 3 and 6 pound (1.4 and 2.7 kg) systems. Must be installed in accordance with FIRETRACE[®] Manual P/N: 800023, dated October 2002.

Manufactured by:

**Firetrace International LLC
15690 N. 83rd Way, Suite B
Scottsdale, Arizona 85260**

FM Approvals Standard Class 5612

Project Identifier: 3012576

Date of Approval: November 5, 2002



Member of the FM Global Group

A handwritten signature in black ink, appearing to read 'Richard B. Dunne'.

Richard B. Dunne, Group Manager
FM Approvals – Hydraulics Group

December 23, 2008
Date